


Project: Gripple Hangers
Client: Gripple Ltd
Client's Order No: 8624
Inspection Date:
First: 19/12/2007

Certificate No: COV 0719796
Office: Sheffield
Date: 19/01/2008
Order Status: Complete
Final: 21/01/2008

This certificate is issued to Gripple Ltd to certify that the undersigned surveyor did, at their request attend their premises at The Old West Gun Works, Sheffield on and between the above dates for the purpose of examining and witnessing tests on the items listed below. All tests produced satisfactory results.

TEST CONFIGURATION



M Cobb
 Surveyor of Lloyd's Register

WITNESSED / REVIEWED
 Lloyd's Register
 EMEA
 Company No: 261109

Gripple Model	Rope Construction	Gripple Rated Load	Gripple Load Limit 5:1	Result		
				80.7 kg 177.5 lbs	76.0 kg 167.2 lbs	79.9 kg 175.8 lbs
No.1 Y-Fit Toggle	7x7 (6/1)	0 -10 kg 0 - 22 lbs	50kg 110 lbs	295.3 kg 649.7 lbs	276.1 kg 607.4 lbs	280.6 kg 617.3 lbs
No.2 Y-Fit Toggle	7x7 (6/1)	10 - 45 kg 22 - 100 lbs	225kg 500 lbs	576.7 kg 1268.7 lbs	490.9 kg 1080.0 lbs	536.8 kg 1181.0 lbs
No.3 Y-Fit Toggle	7x7 (6/1)	45 - 90 kg 100 - 200 lbs	450 kg 990 lbs			